

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180820-S36086  
**Report Reference** S36086-20180814  
**Issue Date** 2018-August-20

**Issued to:** ZETA ALARMS LTD  
Detection House  
72-78 Morfa Rd  
Hafod, Swansea, GB SA1 2EN  
United Kingdom

**This is to certify that  
representative samples of**

HEAT-AUTOMATIC FIRE DETECTORS

Heat Detector head, intelligent (addressable), Model VDOT-H2, combination 135 °F (57.2 °C) fixed temperature and 15 °F/min (8.3 °C/min) rate of rise.

Heat Detector head, intelligent (addressable), Model VDOT-H2-H, 181.4 °F (83.0 °C) fixed temperature.


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 521 - Safety for Heat Detectors for Fire Protective Signaling Systems.

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

