

CERTIFICATE OF COMPLIANCE

Certificate Number 20180820-S36086
Report Reference S36086-20180814
Issue Date 2018-AUGUST-20

Issued to: ZETA ALARMS LTD
Detection House, 72-78 Morfa Rd, Hafod, Swansea, GB
SA1 2EN, United Kingdom

This is to certify that representative samples of HEAT-AUTOMATIC FIRE DETECTORS
Detector, Model VDOT-PYH, Smoke/heat detector head,
with 135 °F fixed temperature and 15 °F Rate of Rise
temperature thermistor.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 268, Standard for Safety for Smoke Detectors for
Fire Alarm Systems; ANSI/UL 521, Standard for Safety for
Heat Detectors for Fire Protective Signaling Systems.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

