

CERTIFICATE OF COMPLIANCE

Certificate Number 20180820-S36085
Report Reference S36085-20180815
Issue Date 2018-August-20

Issued to: ZETA ALARMS LTD
Detection House
72-78 Morfa Rd
Hafod, Swansea, GB SA1 2EN
United Kingdom

**This is to certify that
representative samples of**

**SMOKE-AUTOMATIC FIRE DETECTORS; HEAT-
AUTOMATIC FIRE DETECTORS**

Fire Alarm Subassembly:
Photoelectric, analog addressable, Smoke/Heat detector
head, Model VDOT-DPH with 135 °F (57 °C) fixed
temperature and 15 °F (8.3 °C) Rate of Rise temperature
thermistor.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 268 - SAFETY FOR SMOKE DETECTORS FOR
FIRE ALARM SYSTEMS.
ANSI/UL 521 - SAFETY FOR HEAT DETECTORS FOR
FIRE PROTECTIVE SIGNALING SYSTEMS.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

